



Classification report – Moelven Wood AS

# Classification report for roof exposed to external fire

*Cu Takbord Endepløyd*

NS-EN 13501-5:2016

Author:

Dag Olav Snersrud



## 3 Classification and field of application

### 3.1 Reference

This classification has been carried out in accordance with NS-EN 13501-5:2016.

### 3.2 Classification

The roof *Cu Takbord Endepløyd* with square density of 13.5 kg/m<sup>2</sup> in relation to its external fire performance is classified:

***B<sub>ROOF</sub> (t2)***

## 4 Field of application

This classification is valid for the following conditions:

- **range of pitches:** - all pitches.
- **range of substrates:** - combustible and non-combustible substrates, having a density  $\geq 15$  kg/m<sup>3</sup>.

## 5 Limitations

This document does not represent type approval or certification of the product.